

DISTRICT TRACER WIRE POLICY

PRAIRIE SANITARY DISTRICT, WISCONSIN

As of the effective date of this policy, all new plastic underground sewer piping shall have a continuous 12 gauge (or larger) green insulated copper tracer wire installed with and attached to the plastic sewer piping material. This wire shall extend from the sewer pipe connection at the property right-of-way line to the connection at the building drain. This tracer wire shall terminate (in a visible location) 12" above ground at the sewer/building drain connection.

Effective Date: July 6, 2017